

- 100 Ω Platinum RTD
- 316 Stainless Steel Probe
- Capture Minimum and Maximum Readings

- Selectable Units
- NEMA 4X Housing
- Fits Standard Thermowells

Specifications

Ranges and Resolution

-58.0°F to 392.0°F or -50.0°C to 200.0°C
 Extrapolated range for out-of-range conditions
 0.1 degree resolution
 User selectable °F or °C

Accuracy

Includes linearity, hysteresis, repeatability
 ±0.3°C at 0°C, ±1.1°C at 150°C
 11-point linearization

Display

4 readings per second nominal display update rate
 4 digit LCD, 0.5" H
 5 character 0.25" H alphanumeric
 BL models: red LED backlight

Two front panel bi-color red/green LEDs for alarm status indication

ALARM1 temperature over range indication
 ALARM2 temperature under range indication

Relay Output

Two independent SPDT relays
 0.5A/115VAC, 1A/24VDC, non-inductive
 Alarm status updated 4 times per second nominal
 Alarm configuration mode can be pass code protected
 Each alarm programmable for either HI or LO set point
 Each alarm programmable for deadband in degrees
 Selectable upscale or downscale burnout
 Selectable normal or reverse alarm action

Factory defaults: °F temperature scale, SP1 HI, SP2 LO, 1° deadband, downscale burnout, normal alarm action, configuration and test mode not pass code protected.

3 ft long, 6-conductor 22 AWG cable for relays

Power

8 to 24 VAC 50/60 Hz or 9 to 32 VDC
 Reverse polarity protected
 3 ft long, 2-conductor 22 AWG cable for power

Sensor

IEC-751 Class B 100 Ω Platinum RTD, 0.00385 alpha curve
 ½" NPT male, 316 stainless steel
 Spring-loaded probe versions fit standard thermowells

Controls & Functions

4 button front keypad for setup, calibration, and configuration.
 Multi-level user-defined pass codes to prevent unauthorized changes.
 Pass code optional for output test and set point changes.
 Pass code required for configuration and calibration.

Output Test Function

Test mode to toggle alarm relays
 Output test function can be pass code protected

Calibration

User settable pass code required to enter calibration mode
 Zero and span temperature calibration
 Non-interactive zero, span, and linearity, ±10% of range

Weight

Product: 12 ounces (approximately)
 Shipping: 1 pound (approximately)

Housing Material

ABS/polycarbonate NEMA 4X case, rear gasket, polycarbonate label, aluminum sensor block

Storage Temperature

-40 to 203°F (-40 to 95°C)

Operating Range

-4 to 185°F (-20 to 85°C) at housing



ThermoPro T16ADA Temperature Alarm


Thermowell Stem Length

See thermowell manufacturer's specifications. Probe length is measured from top of full threads to tip of probe.

Quick Link
cecomp.com/thermopro



Dimensions



Wiring

2-conductor 22 AWG power cable	
BLACK	8 to 24 VAC 50/60 Hz or 9 to 32 VDC
RED	

6-conductor 22 AWG relay cable		
BLACK	Normally Closed (NC)	SPDT 1
RED	Common (C)	
WHITE	Normally Open (NO)	
GREEN	Normally Closed (NC)	SPDT 2
BROWN	Common (C)	
BLUE	Normally Open (NO)	

Alarm Contact Ratings
 0.5A/115VAC, 1A/24VDC, non-inductive

Cecomp maintains a constant effort to upgrade and improve its products. Specifications are subject to change without notice. Consult factory for your specific requirements.

How to Order

If you require a certain configuration to be pre-set from the factory, please indicate it on your order.

Option—add to end of model number

-CC Conformal coating on circuit board for moisture resistance

Model	Length	Backlighting	
T16ADA2	2.5" L fixed length	None	
T16ADA4	4" L fixed length		
T16ADA6	6" L fixed length		
T16ADA9	9" L fixed length		
T16ADA12	12" L fixed length		
T16ADA2S	2.5" L spring-loaded		
T16ADA4S	4" L spring-loaded		
T16ADA6S	6" L spring-loaded		
T16ADA9S	9" L spring-loaded		
T16ADA12S	12" L spring-loaded		
T16ADABL2	2.5" L fixed length		Red LED display backlight
T16ADABL4	4" L fixed length		
T16ADABL6	6" L fixed length		
T16ADABL9	9" L fixed length		
T16ADABL12	12" L fixed length		
T16ADABL2S	2.5" L spring-loaded		
T16ADABL4S	4" L spring-loaded		
T16ADABL6S	6" L spring-loaded		
T16ADABL9S	9" L spring-loaded		
T16ADABL12S	12" L spring-loaded		

Precautions


Read these instructions before installation. Configuration may be easier before installation.
 Install or remove thermometer using a wrench on the hex fitting only. Do not attempt to turn by forcing the housing.
 Use a thermowell appropriate for the process.
 Do not exceed maximum allowable housing temperature.
 Due to the hardness of 316 stainless steel, it is recommended that a thread sealant be used to ensure leak-free operation.

Normal Operation





To turn the unit on, apply power. If so equipped, the optional display backlighting will be on. The display backlighting will not be apparent under bright lighting conditions.
 The display segments are tested for approximately 1 second. During the startup sequence, the alarm relays are de-energized and the alarm status LEDs are off.
 The actual temperature and units are displayed and updated approximately 4 times per second.
 The factory default configuration is °F, downscale burnout, Setpoint 1 High Alarm, Setpoint 2 Low Alarm, 1.0 degree alarm deadband, normal acting relays, no pass code required for configure/test alarms mode.

After power-up, the display, the alarm relay states will correspond to the temperature of the RTD probe.

Display and Keypad




Display Out-of-Range Indications

RTD over-range condition $>392.0^{\circ}\text{F}$ or $>200.0^{\circ}\text{C}$ 
 RTD under-range condition $<-58.0^{\circ}\text{F}$ or $<-50.0^{\circ}\text{C}$ 
 If the RTD temperature is outside of the extrapolated range, a burnout condition will be assumed.
 1. . . . if upscale burnout is selected 
 -1. . . . if downscale burnout is selected. 

Alarm Indications

The relevant bi-color LED will be illuminated green for a normal condition or red for an alarm condition.
 The red LED will blink at a slow rate until the alarm is acknowledged or the alarm condition clears.
 To acknowledge an alarm condition, press and release the TEST button.




Viewing Alarm Trip Points

The RTD temperature, the value of Trip Point 1, and the value of Trip Point 2 may be selected for display as follows.


When the RTD temperature is being displayed, press and release the SEL (select) button. The Trip Point 1 value will be displayed with TRIP1 on the lower display.



When the Trip Point 1 value is being displayed, press and release the SEL button. The Trip Point 2 value will be displayed with TRIP2 on the lower display.




When the Trip Point 2 value is being displayed, press and release the SEL button. The RTD temperature will be displayed.



Alarm Test Mode (continued)


While in the Alarm Test Mode with no buttons pressed, the display will indicate the temperature with DEG C or DEG F slowly blinking on the lower display.

Blinking temperature units indicates Alarm Test Mode.



While the TEST button is pressed and held, both LED indicators and alarm relays will toggle to their opposite state. The display will continue to indicate the temperature.

Alarm LEDs and relays toggle to opposite state.




To exit the Alarm Test Mode, press and release the SEL button. The display briefly indicates - - - - and then returns to normal operation.


Adjusting Set Point 1

Alarm 1 factory default:
 HI alarm, 392.0°F trip point.


From the normal mode press the SEL button to display Trip Point 1. Release the SEL button.




While TRIP1 is displayed, press and hold the TEST button and then press the SEL button.



Release both buttons when the display indicates - - - -.



If pass code protection is enabled, before the unit enters the Alarm Test Mode, the display indicates - - - - with the left-most underscore blinking, and with TSTPC on the lower display. Enter the user-defined pass code (3510 factory default) as described in the Pass Code Entry section.




Note: During pass code entry the LEDs will turn off and the unit will not respond to changes in RTD temperature. The alarm relays will maintain their prior states. The unit will automatically revert to normal operation if no buttons are operated for approximately 15 seconds.
 Continued...

Alarm Test Mode

This mode allows testing of the alarms regardless of the alarm trip points or the temperature reading.


From the normal mode with temperature being displayed, press and hold the TEST button and then press the SEL button.



Release both buttons when the display indicates - - - -.



If pass code protection is enabled, before the unit enters the Alarm Test Mode, the display initially indicates - - - - with the left-most underscore blinking, and with TSTPC on the lower display. Enter the user-defined pass code (3510 factory default) as described in the Pass Code Entry section.



Note: During pass code entry the LEDs will turn off and the unit will not respond to changes in RTD temperature. The alarm relays will maintain their prior states. The unit will automatically revert to normal operation if no buttons are operated for approximately 15 seconds.

Adjusting Set Point 1 (continued)

While in the Set Point 1 Adjust Mode, the display will indicate Trip Point 1 with TRIP1 blinking at a slow rate on the lower display.


To adjust Set Point 1, press and hold the TEST button and the display will indicate SP1 on the lower display. If the alarm is not tripped the display will change by an amount equal to the deadband value.

While holding the TEST button operate the ▲ and ▼ buttons to adjust Set Point 1 to the desired value. The Set Point 1 value is stored when the TEST button is released.

Note that the unit will not respond to changes in temperature, LEDs are turned off, and the alarm relays will maintain their prior states while the TEST button is held.

To exit the Set Point 1 Adjust Mode, press and release the SEL button. The display briefly indicates - - - - and then returns to normal operation.

"Set Point" is defined as the temperature that will result in a change of state only from a normal to an alarm condition. "Trip Point" is defined as the value of RTD temperature that will result in a change of state of alarm condition, and includes the effect of deadband when returning from an alarm to a normal condition.



Adjusting Set Point 2 (continued)

During pass code entry the LEDs will turn off and the unit will not respond to temperature changes. The alarm relays will maintain their prior states. The unit will automatically revert to normal operation if no buttons are pushed for 15 seconds.

While in the Set Point 2 Adjust Mode, the display will indicate Trip Point 2 with TRIP2 blinking at a slow rate on the lower display.


To adjust Set Point 2, press and hold the TEST button and the display will indicate SP2 on the lower display. If the alarm is not tripped the display will change by an amount equal to the deadband value.

While holding the TEST button operate the ▲ and ▼ buttons to adjust Set Point 2 to the desired value. The Set Point 2 value is stored when the TEST button is released.

Note that the unit will not respond to changes in temperature, LEDs are turned off, and the alarm relays will maintain their prior states while the TEST button is held.

To exit the Set Point 2 Adjust Mode, press and release the SEL button. The display briefly indicates - - - - and then returns to normal operation.

"Set Point" is defined as the temperature that will result in a change of state only from a normal to an alarm condition. "Trip Point" is defined as the value of RTD temperature that will result in a change of state of alarm condition, and includes the effect of deadband when returning from an alarm to a normal condition.



Adjusting Set Point 2


Alarm 2 factory default: LO alarm, -58.0°F trip point.

From the normal mode press the SEL button until Trip Point 2. Release the SEL button.

While TRIP1 is displayed, press and hold the TEST button and then press the SEL button.

Release both buttons when the display indicates - - - -.

If pass code protection is enabled, before the unit enters the Alarm Test Mode, the display indicates - - - - with the left-most underscore blinking, and with TSTPC on the lower display. Enter the user-defined pass code (3510 factory default) as described in the Pass Code Entry section.



Pass Code Entry

Before the unit enters a pass code protected mode, the display initially indicates - - - - with the first underscore blinking, and with CFGPC, CALPC, or TSTPC on the lower display, depending on how the mode was entered.

Note that the unit will not respond to changes in temperature, LEDs are turned off, and the alarm relays will maintain their prior states while in the pass code entry mode.

The unit will automatically revert to normal operation if no buttons are operated for approximately 15 seconds.


Enter the user-defined pass code (3510 factory default).

Use the ▲ and ▼ buttons to increase or decrease the numerical value.

Press and release the SEL button to index to the next position.

Once the 4-digit user-defined pass code has been entered, press and release the SEL button to proceed to the specific mode of operation.

Note: If an incorrect pass code was entered, the unit will exit to the normal operating mode.



Pass Code Modification

During pass code entry the LEDs will turn off and the unit will not respond to temperature changes. The alarm relays will maintain their prior states. The unit will automatically revert to normal operation if no buttons are pushed for 15 seconds.

Configuration Pass Code

From the normal operating mode press and hold the TEST and the ▲ buttons. Then press the SEL button. Release all buttons when the display indicates CFG. The display initially indicates - - - - with the first underscore blinking, and with CFGPC on the lower display.

Calibration Pass Code

Press and hold the TEST and the ▼ buttons. Then press the SEL button. Release all buttons when the display indicates CAL. The display initially indicates - - - - with the first underscore blinking, and with CALPC on the lower display.

Test and Set Point Adjust Pass Code (optional)

The option for pass code protected alarm testing or set point changes is set in CFG mode.

Press and hold the TEST button. Then press the SEL button. Release all buttons when the display indicates - - - -.

If TSTPC pass code is enabled, the display indicates - - - - with the first underscore blinking, and TSTPC on the lower display.

Factory Pass Code Entry (1220 factory default)

Use the ▲ and ▼ buttons to increase or decrease the numerical value.

Press and release the SEL button to index to the next position.


Once the 4-digit user-defined pass code has been entered, press and release the SEL button to proceed. If an incorrect pass code was entered, the unit will exit to the normal operating mode.

Once the correct password has been entered, the display will indicate the existing pass code with CFGPC, CALPC, or TSTPC on the lower display.

Operate the ▲ or ▼ button to select the first character of the new pass code. Press and release the SEL button to proceed to the next character. Repeat until the entire pass code is complete. Write down the new pass code in a secure place.

To exit the Pass Code Modification mode, press and hold the SEL button. Release the button when the display indicates - - - - to restart the unit in the normal mode.

The unit proceeds through a restart sequence during which all active display segments are turned on for approximately 1 second. During the restart sequence, the alarm relays are de-energized and the alarm status LEDs are off.




Calibration

Temperature calibration is performed at two points: ice point and at a temperature above ice point. For general service, the full scale temperature is normally used for the second point. However, if a particular temperature is of critical interest, it may be used instead for greatest accuracy at that point. When the applied temperature is below approximately 12 °C (or 54 °F), the unit will automatically select the ice-point calibration mode.

Entering Calibration Mode

From the normal mode with RTD temperature being displayed, press and hold the TEST and the ▼ buttons. Then press the SEL button. Release all buttons when the display indicates CAL.



Enter the user-defined pass code (3510 factory default) as described in the Pass Code Entry section.




Upon successful pass code entry, the upper segments of the display will indicate the RTD probe temperature. The lower segments of the display will alternate as indicated below.

Note: To store the calibration parameters and exit calibration mode at any time, press and hold the SEL button until the display indicates - - - - .

Ice-Point Calibration


Apply 0.0°C or 32.0°F to the RTD. The lower display segments will alternate between ICE and DEG C or DEG F.



Use the ▲ and ▼ buttons to adjust the upper display segments to indicate 0.0°C or 32.0°F.

Span Calibration


Apply full-scale temperature to the RTD. The lower display segments will alternate between CAL and DEG C or DEG F.



Use the ▲ and ▼ buttons to adjust the upper display segments to indicate the applied temperature value.

Exit and Save


To store the calibration parameters and exit calibration mode, press and continue to hold the SEL button until the display indicates - - - - .




Entering User Configuration Mode

Note: Whether or not configuration changes are made, all alarm set points will be reset to the maximum and minimum values respectively upon exit from the configuration mode.

From the Normal Mode with RTD temperature being displayed, press and hold the TEST and the ▲ buttons. Then press the SEL button. Release all buttons when the display indicates CFG.




Enter the user-defined pass code (3510 factory default) as described in the Pass Code Entry section.




Temperature Scale Selection

The upper display will be blank, and the lower section will display either DEG C or DEG F.

To change from degrees Celsius to Fahrenheit, press and release the ▲ button. The lower display will change to DEG F.



To change from degrees Fahrenheit to Celsius, press and release the ▼ button. The lower display will change to DEG C.




Press and release the SEL button to move on to the next parameter.


Upscale/Downscale Burnout Action

The upper display will be blank, and the lower section will display either DN BO or UP BO.

To change from Downscale Burnout to Upscale Burnout, press and release the ▲ button. The lower display will change to UP BO.



To change from upscale burnout to downscale burnout, press and release the ▼ button. The lower display will change to DN BO.




Press and release the SEL button to move on to the next parameter.


Set Point 1 LO or HI

The upper display will be blank, and the lower section will display either SP1LO or SP1HI.

To configure Setpoint 1 as a High Alarm, press and release the ▲ button. The lower section of the display will indicate SP1HI.



To configure Setpoint 1 as a Low Alarm, press and release the ▼ button. The lower section of the display will indicate SP1LO.




Press and release the SEL button to move on to the next parameter.


Set Point 2 LO or HI

The upper display section will be blank, and the lower section will display either SP2LO or SP2HI.

To configure Setpoint 2 as a High Alarm, press and release the ▲ button. The lower section of the display will indicate SP2HI.



To configure Setpoint 2 as a Low Alarm, press and release the ▼ button. The lower section of the display will indicate SP2LO.




Press and release the SEL button to move on to the next parameter.


Normal/Reverse Alarm Action

The upper display section will be blank, and the lower section will display either NOR or REV.

To configure the relays for reverse action, press and release the ▲ button. The lower section of the display will indicate REV.



To configure the relays for normal action, press and release the ▼ button. The lower section of the display will indicate NOR.




Press and release the SEL button to move on to the next parameter.

Set Point 1 Deadband

The upper display will indicate the Setpoint 1 deadband in °C or °F, and the lower section will display SP1DB.

Use the ▲ and ▼ buttons to set the desired Setpoint 1 deadband value.




Press and release the SEL button to move on to the next parameter.

Set Point 2 Deadband

The upper display will indicate the Setpoint 2 deadband in °C or °F, and the lower section will display SP2DB.

Use the ▲ and ▼ buttons to set the desired Setpoint 2 deadband value.




Press and release the SEL button to move on to the next parameter.


Test Mode and Set Point Security

The upper display will be blank, and the lower section will display either TSTPC or NOTPC.

To enable Test and Set Point Adjust Mode pass code protection, press and release the ▲ button. The lower section of the display will indicate TSTPC.



To disable Test and Set Point Adjust Mode pass code protection, press and release the ▼ button. The lower section of the display will indicate NOTPC.



Save Settings and Exit

Press and release the SEL button to save the configuration parameters and restart the unit. Note: The configuration parameters will not be saved if the procedure is interrupted before completion.

The unit proceeds through a restart sequence during which all active display segments are turned on for approximately 1 second. During the restart sequence, the alarm relays are de-energized, the alarm status LEDs are off.